

SISTEMA SANCAD - PLANILHA DE DADOS FINAIS

25 DE JULHO

TRECHO 3

REVISÃO 02

20/03/2015

L:\EG0185 - REDES ESGOTOS PELOTAS\ARQ TRABALHO\SANCAD\25 JULHO\REV02\TRECHO 3\SANCAD 25J 5.2.3_REV02.DBF

Coletor	PVM	PVJ	Comp (m)	CTM (m)	CTJ (m)	CCM (m)	CCJ (m)	PRFM (m)	PRFJ (m)	Diam (m)	Decl (m/m)	Q Real Ini (l/s)	Q Real Fim (l/s)	Veloc Ini (m/s)	Veloc Fim (m/s)	Trativa (Pa)	H/D Ini	H/D Fim	Observ.
003-001	25J-010	25J-011	55.00	14.982	15.979	12.982	12.707	2.000	3.272	0.150	0.00500	0.324	0.508	0.52	0.52	2.64	1.00	0.22	0.22
003-002	25J-011	25J-012	90.00	15.979	16.729	12.707	12.257	3.272	4.472	0.150	0.00500	0.854	1.339	0.52	0.52	2.64	1.00	0.22	0.22 DG 0.007
003-003	25J-012	25J-013	93.00	16.729	17.269	12.250	11.785	4.479	5.484	0.150	0.00500	1.402	2.198	0.52	0.58	2.87	1.00	0.22	0.27 DG 0.007
003-004	25J-013	25J-014	100.00	17.269	13.250	11.778	11.243	5.491	2.007	0.150	0.00535	1.991	3.122	0.57	0.65	3.07	1.18	0.25	0.32
003-005	25J-014	25J-015	100.00	13.250	11.837	11.243	9.837	2.007	2.000	0.150	0.01406	2.580	4.046	0.87	0.99	2.93	2.81	0.22	0.28 DG 0.050
003-006	25J-015	25J-016	75.00	11.837	11.517	9.787	9.467	2.050	2.050	0.200	0.00427	3.021	4.739	0.58	0.66	3.37	1.13	0.22	0.28
003-007	25J-016	FIM	10.00	11.517	11.474	9.467	9.424	2.050	2.050	0.200	0.00430	3.080	4.831	0.59	0.67	3.38	1.15	0.22	0.28 FIM

